

# 56 SERIES

## USE OF CAPS AND SEALANT FOR FULL IP66 APPLICATIONS

Ensure all the screws are covered with the appropriate caps enclosed.

*Before fitting bridge, apply sealant to slots (see illustration)*

Conduit entry points may require sealing due to condensation.

Suitable silicone sealants:

Dow Corning 732


Dow Corning 1080

Dow Corning 739 Plastic Adhesive

Selleys Window and Glass Sealant

Ramset RC 804

Ados Neutral Cure Sealant



### WARNING

IP66 rating can only be ensured when used with PDL 56 Series enclosures. Use only recommended silicone sealants

### INSTALLATION ELECTRICIAN PLEASE NOTE

During transit, factory-fitted internal wiring connections may have loosened. Check the terminal screws for tightness before completing installation.



**PDL**

