



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA170553

Certificate Holder: The Trustee for PGK Distributors Unit Trust T/as
PGK Distribution
2a/62 Secam Street
Mansfield QLD 4122
Australia

Class Description: Non-Declared
Product Description: PV Switch Disconnecter

Brand Name:



Model No.:

SE030A

Markings:

1000Vdc Max, 50A Max
ta:-40 to +85°C, DC-21B, DC-PV2, IP66

Standard:

IEC 60947-1 Ed 5.2
IEC 60947-3 Ed 3.2

Conditions:

Nil

Certification Mark: SAA170553 or RCM

Date First Registered: 23 March 2017

Date of Expiry: 23 March 2022


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 23-03-17 170553/1



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA170553

Date of Issue: 23 March 2017

Class Description: Non-Declared

Product Description: PV Switch Disconnecter

Additional Models	Description
SE030B	Similar to SE030A except with PV-connector
SE030E	Similar to SE030B except with different PV-connector.
SE030C	Similar to SE030A except rated 1200Vdc
SE030D	Similar to SE030C except with PV-connector.
SE030F	Similar to SE030D except with different PV-connector.
SE030N	Similar to SE030C except without enclosure and for panel mounting.
SE030M	Similar to SE030C except without enclosure and for DIN rail mounting.


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 23-03-17 170553/2